## ΤΛϹΜΙΝΛ

# Solenoid-driven Diaphragm Metering Pump

# 



www.tacmina.com

## Safe, Easy and Long-life

Relief-valve function, wide voltage range, easy operation, tough body, extensive selection of liquid-end materials, wide discharge-volume range, various control functions ...and many more. TACMINA's lineup of solenoiddriven diaphragm-type metering pumps, highly reliable and top-quality pumps, will answer all kinds of customers' chemical injection requirements.

		Model Selection by Application		Model Selection Guide
Small Capacity	S-size only S-size only	PZ Manual Setting	PZ No-input	ΡZ
Small Capacity	Standard     Joint Construction     Joint Construction       High-viscosity     Boiler	<b>PWW</b> Digital Setting Multi Functions	PWDigital-input/outputPWMDigital-input/output & Analog-inputPWTDigital-input/output & Timer Control	PW
Middle Capacity	PZD PZI	PZD Digital Setting Digital Setting Advanced Functions	PZDNo-inputPZi4Digital-input & Analog-inputPZi8Digital-Input/Output& Analog-Output	PZI/PZD
Large Capacity	Standard High-viscosity type	<b>PZIC</b> Digital Setting Advanced Functions	PZiG Digital-input/output & Analog-input	PZIG
For Sodium Hypochlorite	DCLPW CLPW CLPZ	Air Block In-Line Automatic Air-release CLPW In-Line Automatic Air-release	DCLPW DCLPWMDigital-input/output bigital-input/output & Analog-inputDCLPWTDigital-input/output & Timer ControlCLPW CLPWMDigital-input/output & Analog-inputCLPWT CLPWTDigital-input/output & Analog-inputCLPWT Digital-input/output & Analog-inputDigital-input/output & Analog-inputCLPWT CLPWTDigital-input/output & Analog-inputCLPWT Digital-input/output & No-InputDigital-input/output & Digital-input/output & 	DCLPW/CLPW/CLPZ
For Sodium Hypochlorite	ARPZ	AR Automatic Air-release	ARPZ No-input	AR
		<ul> <li>Application</li> <li>Explanation &amp; Co</li> <li>Related Equips</li> </ul>	prrosion-resistance Table ment & Option	OTHER

## **By Application**

## For Injection of General Chemicals

Se	ries		Sm	all C	apa	city				\$	Smal	l Ca	pacit	ty	Mid	dle (	Capa	city	Lar	ge C	apa	city
			_	PZ Manual	Setting	)				ġ	Digital S Aulti Fu		S PW	Μ	Pz Digital		Adva		Digi		ing <b>P</b> Functio	_
			w/ReliefV	alve		1			/ Relief Va	alve			À		ġ					4		
Model		30R	60R	100R	30	60	100	30R	60R	100R	30	60	100	200	300	500	300	500	300	500	700	1000
May diasharga	mL/min	30	60	100	30	60	100	30	60	100	30	60	100	220	360	540	360	540	340	530	760	1000
Max.discharge volume	L/h	1.8	3.6	6.0	1.8	3.6	6.0	1.8	3.6	6.0	1.8	3.6	6.0	13.2	21.6	32.4	21.6	32.4		31.8		60.0
	US G/h		0.95	1.58	0.47	0.95	1.58	0.47	0.95	1.58	-	0.95	1.58	3.48	5.7	8.55	5.7	8.55		8.39	12.03	15.84
Max.discharge	MPa	0		0.4	1.0	0.8	0.4		0.7			.0	0.7	0.2	0.3	0.2	0.3	0.2	1.0	0.7	0.4	0.3
pressure	bar		.0	4.0	10.0	8.0	4.0		7.0			).0	7.0	2.0	3.0	2.0	3.0	2.0	10.0	7.0	4.0	3.0
•	psi	10	1.5	58	145	116	58		101.5		14	15	101.5	29	43.5	29	43.5	29	145	101.5	58	43.5
Max.allowable viscosity	mPa∙s			$\sim 5$	0						~	~50			~ţ	50	~Ę	50		$\sim 5$	0	
Relief valve func	tion		0			_			0			_		_	-	_	-	_		_	_	
Signal				No-i	nput					PW PW PW	M Di Ar T Di	gital-in alog-ii	put/out	tput &	PZ No-i	D nput	PZi4 Digital-i Analog- PZi8 Digital-inp Analog-in	input ut/output &	Dig	<b>ZiG</b> jital-inp alog-inj	ut/outp out	ut &
Liquid-end mater	rial					P٧	′C/PV	DF/S	US					PVC	P٧	/C/PV	/DF/S	US		PVC	/PVDI	F
Reference page			GO P		admathdiated	and a state					G0 to P7	a and a			GO			1000	G0 P 1	17 🗐		

## For Injection of Boiler / High-pressure

Se	ries	Small C	apacity	S	mall Capaci	ty
		<b>PZ</b> Manual	Setting		Digital Setting Multi Functions	/M
		w Relicivalve		(For boiler) W Relief Valve	(For boiler)	(For highpressure liquids)
Model		30R	30	30R	30	30
	mL/min	2	8	2	8	25
Max.discharge	L/h	1.6	68	1.6	68	1.5
volume	US G/h	0.4	44	0.4	44	0.39
Max diasharga	MPa	1.	5	1.	.5	2.0
Max.discharge pressure	bar	15	i.O	15	i.O	20.0
p. 0000.0	psi	21	7.5	21	7.5	290
Max.allowable viscosity	mPa∙s	$\sim$	50		$\sim$ 50	
Relief valve func	tion	0	_	0	-	_
Signal		No-i	nput	PW PWI PW1	Analog-input	put &
Liquid-end mater	rial			PVC		
Reference page		GO to P 5			GO to P7	

om temperature. The maximum discharge volume and maximum discharge pressure may differ slightly according to material and specifications. For details on each product, see the reference page for the respective model.

## For Injection of Sodium Hypochlorite

	-								-													
Se	eries		Air I -Line /	<b>PW</b> Block Automa elease		DCLF DCLF DCLF	WM		Aut	PW -Line omatic release		LPW LPWN LPW1				CL	PZ				RP Automati Air-releas	
			w/ Relief	Valve					Relief Valv	7C					Relief Val	Ve	(	3		4	9	
Model		30R	60R	100R	30	60	100	30R	60R	100R	30	60	100	30R	60R	100R	30	60	100	31	61	12
NA 11 1	mL/min	30	60	90	30	60	90	30	60	90	30	60	90	30	60	100	30	60	100	27	54	93
Max.discharge volume	L/h	1.8	3.6	5.4	1.8	3.6	5.4	1.8	3.6	5.4	1.8	3.6	5.4	1.8	3.6	6.0	1.8	3.6	6.0		3.24	
	US G/h	0.47		1.42				0.47		1.42										0.42	_	1.47
Max.discharge	MPa		0.7		1.	0	0.7		0.7		1	.0	0.7	0	7	0.4	1.0	0.8	0.4	1.0	0.8	0.4
pressure	bar		7.0		10	-	7.0		7.0		10	-	7.0	7.	-	4.0	10.0	8.0	4.0	10.0	8.0	4.0
·	psi		101.5	5	14	15	101.5	-	101.5		14	15	101.5	10	1.5	58	145	116	58	145	116	58
Max. allowable viscosity	mPa∙s										-	~50										
Relief valve fund	ction		0			_			$\bigcirc$			_			0			_			_	
Deligital-input/output       Deligital-input/output       Deligital-input/output       Deligital-input/output         Signal       Deligital-input/output       Deligital-input/output & Analog-input       CLPW       Digital-input/output & Analog-input         Deligital-input/output       Deligital-input/output       CLPWT       Digital-input/output & Analog-input       No-input         Deligital-input/output       Deligital-input/output & Timer Control       CLPWT       Digital-input/output & Timer Control									-													
Liquid-end mate	erial	Acrylic (PMMA)																				
Reference page	Э								G0 to P21		Sold Sold Sold Sold Sold Sold Sold Sold								GP	0 to 23		and a second

## **By Function**

#### \* For details on each product, see the reference page for the respective model or "Explanation" on page 26.

Function         Input          2         1         2          2         4         4         2         1         2             Signal Gradout         Input          2         1         2          2         4         4         2         1         2            2         2         2         2			Series		Small C	apacity		Mic	ldle Capa	icity	Large Capacity		For Sodi	um Hypo	chlorite	
Signal No. diports         Digital Output         -         2         -         -         2 <t< th=""><th>Functio</th><th>on</th><th></th><th>PZ</th><th>PW</th><th>PWM</th><th>PWT</th><th>PZD</th><th>PZi4</th><th>PZi8</th><th>PZiG</th><th></th><th></th><th></th><th>CLPZ</th><th>ARPZ</th></t<>	Functio	on		PZ	PW	PWM	PWT	PZD	PZi4	PZi8	PZiG				CLPZ	ARPZ
No digenity         Output         -         2         -         -         2         2         2         2         -		D	Input	_	2	1	2	_	2	4	4	2	1	2		_
Power supply to Flow Checker		Digital	Output	_		2		_	_	2	2		2		_	_
Markal         Stroke speed		Analog	g Input	_	_	1	—	—		1	1	—	1	—	—	—
Manual Percentage         Discharge volume (network)         Image: multipoportional control         Image: multipoporticonal control         Image: multicon <th< td=""><td>Power s</td><td>supply to</td><td>o Flow Checker</td><td></td><td>-</td><td>_</td><td></td><td>—</td><td>—</td><td>0</td><td>-</td><td></td><td>_</td><td></td><td>—</td><td>—</td></th<>	Power s	supply to	o Flow Checker		-	_		—	—	0	-		_		—	—
Percentage		ę	Stroke speed		(	)		0		)	0		0		—	—
Kert         Pulse-input proportional control         O        O         O        O        <		Manual [	Discharge volume		0		_	0				0	-	_		
Analog input proprional control					-	_		0			0		—		—	—
Control         Interval operation		F	Pulse-input proportional control	(	)	_	0	—		)	0	0	-	0	_	_
$ \begin the tent the tent the tent tent tent t$		A	Analog-input proportional control	_	_	0	-	-		)	0	-	0	—	—	_
Control         Auto         Count operation (batch control)            0          0          0		1	nterval operation				0	_	-	0	0	-	_	0		_
Control         Count operation(batch control)            0          0            0		Auto	Timer control		_		0	-	_		_	-	_	0		_
External stop-signal control          O         O <th< td=""><td>Control</td><td></td><td>Count operation(batch control)</td><td></td><td>_</td><td>_</td><td></td><td>-</td><td>_</td><td>0</td><td>0</td><td>-</td><td>_</td><td>0</td><td></td><td>_</td></th<>	Control		Count operation(batch control)		_	_		-	_	0	0	-	_	0		_
Image: Provint Level Switch control*1		E	External operation-signal control			0		-	-		_		0			_
ECO mode   <		E	External stop-signal control			0		-		)	0		0			
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $		2	2-point Level Switch control*1			0		-		C	0		0			_
$\begin{tabular}{ c c c c c c c } \hline \mbox{Relief value} $$ $$ $$ $$ $$ $$ $$ $$ $$ $$ $$ $$ $$$		ECO n	node			0		-	-	_	_		_			_
$\begin{tabular}{ c c c c c c c } \hline \begin{tabular}{ c c c c c } \hline \begin{tabular}{ c c c c c c } \hline \begin{tabular}{ c c c c c c c } \hline \begin{tabular}{ c c c c c c c c c c c c c c c c c c c$		SAFE	mode			0		-	-	_	_		0			
$\begin{tabular}{ c c c c c c c c c } \hline Alarm function & & & 0 & 0 & 0 & 0 & & & $		Relief	valve function					-	-	_	_		0		_	_
Tank-level alarm         w/1-point Level Switch         —         O         —         O         —         …		Alarm	function					-	_	0	0		0			
alarm         w/2-point Level Switch		Memory	/-read error (LCD display only)			_		0		)	0		_			_
alarm         w/2-point Level Switch		Tank-l	evel w/1-point Level Switch	_		0		_		)	0		0			_
Alarm     Analog-Input error     —     O     —     O     O     O     O     —     —       Lower discharge-volume alarm*2     —     … <td< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>_</td><td>_</td><td>0</td><td></td><td></td><td>_</td><td></td><td></td><td>_</td></td<>								_	_	0			_			_
Analog-Input error         —         O         —         O         O         O         —         #         #         #         #         #         #         #         #		Pulse-	Input error			0		_	(display only)	0	0		0			_
	Alarm	Analog	g-Input error			0		_	(display only)	0	0		0			_
Easy calibration function — O — O — O O — —		Lower d	lischarge-volume alarm*2					_	(display only)	0	-		_			_
	Easy ca	libratio	n function		0	-	_	0	-	_	0	0	-	-		
Momentary discharge-volume display function*2 —								-	_	0	-					—



#### Wide Voltage **Range Power Supply**

There is no need to worry about site power supply voltage or voltage fluctuations since it can be used with AC100 to 240 V  $(\pm 10\%)$  power supplies. You can also keep it in




#### Simple Structure

Minimum number of parts allows easy maintenance.

Solenoid

Pump shaft

stock safely since it can be used for a variety of sites and applications.



#### Extensive Range of Liquid-end Materials

\* For details, refer to the "Liquid-end Material" table on the following page.



**VTCE/VTCF** Material: PVC Application example:Transfer/injection of general chemicals



#### FTCE/FTCF/FTCT

Material: PVDF Application example:Transfer/injection of special chemicals(e.g. strong and mixed acids)

#### w/ Relief Valve



#### VTCET (for injection of boiler chemicals) Material: PVC Application example:Transfer/injection of boiler chemicals




#### 6TCT

Material: Stainless steel(SUS316) Application example:Transfer/injection of solutions/special chemicals

	Μ	odel				30F	R/30					60F	R/60					100F	R/100		
									VTCET												
Specif	ication		VTCE	VTCF	FTCE	FTCF	FTCT	6TCT	(for injection of boiler chemicals)	VTCE	VTCF	FTCE	FTCF	FTCT	6TCT	VTCE	VTCF	FTCE	FTCF	FTCT	6TCT
		mL/min			30			27	28			60			55			100			95
Max. discha	rge volume*1	L/h			1.8			1.6	1.68			3.6			3.3			6.0			5.7
		US G/h			0.47			0.42	0.44			0.95			0.87			1.58			1.5
		MPa		(	).7[1.0	)]		0.5	1.5		(	).7[0.8	]		0.5			0	.4		
Max. discharg	ge pressure*1	bar			7.0[10	]		5.0	15.0		7	7.0[8.0	)]		5.0			4	.0		
		psi		101.5 [145] 72.5 217.5 101.5 [116] 72.5 58																	
Stroke s	peed			15 to 300 strokes/min (dial setting)																	
Stroke le	ength		Fixed at 1.0 mm																		
Connection	Discharg	ge side	(PVC brai 6	x 8	(P	x 8 PE)	6 x 8 (FEP)	6 x 8	4 x 6 (nylon tube)	(PVC brai 6	(11 ided hose) x 8	(P		6 x 8 (FEP)	6 x 8	6 x 11 (PVC braided hose) 6 x 8 (PE) (PE) (PE) 1/4" x 3/8" 1/4" x 3/8"		6 x 8			
(hose/tube: I.D x O.D)	Suction	side		'E) x 3/8" 'E)		x 3/8" PE)	1/4" x 3/8" (FEP)	(PTFE)	4 x 9 (PVC braided hose)	1/4"	PE) x 3/8" PE)	1/4" : (P	x 3/8" PE)	1/4"x 3/8" (FEP)	(PTFE)	1/4"	6 x 8 (PE) (FEP)			(PTFE)	
	Relief /air-	release								4	x 6 (so	ft PVC	hose)								
Max. allo	wable vis	cosity										mPa∙s									
	e tempera	iture						Ambien	t temperature: 0	to 40°C				o 40°C (	no freez	ing allo	wed)				
	humidity											85% R									
	iental prote								IEC standar	d: IP65				vater-res	sistance	e)					
Noise le	instrallation	location										an 1,00 han 85									
Dperation mode	Manual								Setting strok	e speed				n) w/ ma	anual di	al					
	Rated vo	oltage								AC 1	00 to	240 V	/ (±10	)%)							
Power	No.of phases/	<u> </u>																			
supply	Maximum									· P		.0 A									
,	Power cons									Max.:	200	VA/Av	e.: 15	5 W							
Weigh											1	7 kg									

Model Code \* Not all model combinations are possible. When selecting the pump model, first check "Specification" and "Liquid-end Material".



#### Liquid-end Material


\* Also refer to the "Corrosion-resistance Table" on page 26.


-							
Model Part	VTCE	VTCF	FTCE	FTCF	FTCT	VTCET (for injection of boiler chemicals)	6ТСТ
Pump head	Р	VC		PVDF		PVC	SUS316
Diaphragm				PTFE			
Check ball				Ceramic			
O-ring	EPDM	Fluoro-rubber	EPDM	Fluoro-rubber	Special fluoro-rubber Pafulo <sup>®</sup>	EPDM	PTFE
Valve seat	EPDM	Special fluoro-rubber	EPDM	Special fluoro-rubber	PTFE	PTFE	-
Joint	P	VC		DVDE		PVC	SUS316
Ball stopper	Р	VC		PVDF		PVC	PTFE (valve stopper)

#### Accessory

\* Power cable (2 m) is attached. **External Dimension (mm)** 

Model			3	0R/60 30/60	R/100I 0/100	R				
Item	VTCE	VTCF	FTCE	FTCF	FTCT	6TCT	VTCET (for injection of boiler chemicals)			
Hose/Tube*1			3	m			Discharge side : 2 m Suction side : 1 m			
Relief /air-release hose*1			1 m*2			-	1 m*2			
Anti-siphon check valve			set /2)			set or R3/8)	1 set (R1/2)			
Foot valve				1 :	set					
Ceramic weight	1 s	et*2		1 set			-			
Hose pump for air-release				-		1 set	—			
INSULOK for Relief /air-release hose*3			1 piece			-	1 piece			
Pump mounting nuts/bolts				2 se	ts (M5 x 3	0)				
Operation manual 1 set										





 Model
 (A)
 B
 C
 D
 E
 (F)
 G

 VTCE/VTCF
 206
 152
 76
 76
 16.5
 150.5
 70

 FTCE/FTCF/FTCT
 227.5
 195
 97.5
 97.5
 17.5
 142
 69.5

 VTCET
 193
 139
 76
 63
 16.5
 150.5
 70

 \* The shape and dimensions differ slightly depending on the liquid-end material and connection type.
 \* The mounting pitch allows mounting from 87 to 110 mm.

\* 1 For details on the hose/tube aperture, see "Connection" for the respective model in "Specification" table above.
\* 2 This hose is already attached to 30R/60R/100R models.
\* 3 This accessory is supplied with models with the simple relief valve.

Nd








# Higher Safety

Three types of safety functions that realize higher rank risk management

## SAFE mode for preventing abnormal pressure buildup

While the discharge valve is closed, the liquid transfer force is controlled to prevent pressure buildup.




- \*To use the SAFE mode, set the stroke length to 100%.
- \*The SAFE mode is not available for PW-200, boiler type and high-pressure type. \*The function is disabled at the factory default

setting.

# Relief valve function for releasing abnormal pressure


When the pressure exceeds the setting value, the relief valve operates automatically.




Standard type pump discharge pressure: 0.7MPa. Boiler-type pump discharge pressure: 1.5MPa.
The Relief valve function cannot be selected for SUS type, high-viscosity type, and high-pressure type pumps.

#### Alarm function for notifying abnormal pressure

When abnormal pressure builds up due to clogging of the pipes or while the discharge valve is closed, an alarm is emitted to warn this condition.



- \* When the alarm function is used together with the SAFE mode, an alarm is emitted for pressure lower than the normal pressure.
- \*This function is disabled at the factory default setting.




#### Function correspondence table

			PW/PW	/M/PWT				DCLPW/DCLP CLPW/CLPV	WM/DCLPWT VM/CLPWT
	Genera	al chemical mod	el	High-viscosity	Bo	iler	High-pressure	Sodium hy	pochlorite
	30R/60R/100R	30/60/100	200	60/100	30R	30	30	30R/60R/100R	30/60/100
Relief valve function	0	—	-	—	$\bigcirc$	—	_	0	_
SAFE mode	0	0	×	0	×	×	×	0	0
Alarm function	0	0	0	0	0	0	0	0	0
ECO mode	0	0	×	0	0	0	0	×	×


\* A circle ( $\odot$ ) is indicated for the corresponding function that can be set. A cross (x) is indicated for the corresponding function that must not be set even though it is technically possible.


# Superior Eco-friendly Performance Automatically cuts power-on time in accordance with the discharge pressure

The power of conventional pumps was always turned on for a specific period regardless of the discharge pressure. The ECO mode of PW pumps always monitors operation conditions and automatically shortens the power-on time during low-pressure operation in order to reduce power consumption.



# **Optimal Ease of Use**







# Wide-ranging Control Functions **Realize Ideal Chemical Injection** Systems

### **Common functions**

#### Manual operation

#### Strokes/minute control

The stroke speed can be set in increments of 1 stroke per minute

#### External operation & stop control

The pump can be turned on and off using a input signal from an external device.

#### Synchronous pulse control

A single pulse can be output for a single pump operation. The output pulse can be input to a second pump to perform synchronous operation.


Example: For a single stroke (Pump A), controls such as three strokes (Pump B) and 2 strokes (Pump C) can be enabled.

#### Discharge volume control (PW only)

The discharge volume can be set in increments of 0.1mL per minute.

#### Alarm output

When the pump is used in combination with a level meter and checker, an alarm is output during abnormal pressure buildup.





#### Signal distribution

PW


The following connections are possible without using a signal distributor.

**PWM** 



You can connect multiple instances of this pump in parallel.


**PW1** 




Analog signal

Analog

signal






\* The pumps operate in a linked manner. To operate pumps separately, install a signal distributor.

#### Pulse input-based proportional control



Pulse frequency-division

The pump performs a single injection operation for 'n' times of input pulse signals. Setting range: n = 1 to 999




#### The pump performs Setting example: n = 3 the injection Signal operation 'n' times for a single input pulse signal.

= 1 to 999

Setting range: n





**PWM** 



Analog input signal-based proportional control

## Automatic operation





	Item		PW (pulse type)	PWM (analog type)	PWT (timer type)
	Number of ports	Digital	2	1	2
Input signal	Number of ports	Analog	_	1	_
	Туре		Stop signal, pulse signal	Stop signal, pulse signal	Stop signal, pulse signal
	Number of ports	Digital	2	2	2
Output signal	Туре		Sync pulse, alarm output	Sync pulse, alarm output	Sync pulse, alarm output
		Number of strokes	1 to 30	00 (Enables setting in 1-stroke	units)
	Manual operation	Discharge volume control	0.1 to maximum discharge volume (Enables setting in 0.1mL/minute units)	—	_
Control	Pulse proporti	onal control	•	_	•
	Analog propor	tional control	_	•	_
	Timer control		_	_	•
	External operation	n & stop input signal		•	


#### **Timer control**

#### PWT

#### Interval mode

Pump operation can be turned on and off in accordance with the setting of the timer. You can set any ON and OFF period for one pattern each in the range of 1 to 9999 minutes.


Setting example: ON period: 5 minutes



#### DAY mode

The pump operates automatically everyday using the same ON and OFF timing that is set. You can set up to nine program patterns within the range of 0:00 to 24:00 in 1-minute unit. \* DAY mode cannot be used together with the WEEK mode.

Setting example: ON time: ① 1:00 ② 6:30 ③11:30 ④17:15 OFF time: ①5:00 ②10:30 ③15:15 ④21:15



•When both interval mode and pulse operation are simultaneously set, the pump will operate in accordance with pulse frequency-division or pulse frequency-magnification setting within the ON time set for the DAY mode and interval mode.

#### WEEK mode

The pump automatically operates every week at the same ON and OFF time being set for the day of the week. You can set one program pattern for each day of the week. You can set the ON time from 0:00 to 24:00 and OFF time within the range 0:00 to 48:00 in 1-minute unit. \* WEEK mode cannot be used together with DAY mode.

Settin	g exa	mple	M	on 00	12:00	12:00	12:00	12:00	<b>Fri</b> 0:00	Sat	12:00	Sun	12:00	Mo		
No.1	Mon	ON time	9:00												Time that ear he	
110.1	IVIOII	OFF time	18:00												Fime that can be or each program	
No.2	Tue	ON time	9:00											F	operation t	ime
110.2	Tue	OFF time	24:00													
No.3	Wed	ON time	12:00													
110.0	weu	OFF time	30:00													
No.4	Thu	ON time	9:00													
110.4	Inu	OFF time	36:00	1												
No.5	Fri	ON time	12:00													
110.5	ГП	OFF time	36:00													
No.6	Sat	ON time	-:													
110.0	Sai	OFF time	;	]												
No.7	Sun	ON time	0:00													
110.7	Sun	OFF time	32:00	]												

When the pulse proportional control operation is set, the pump will operate in accordance with the pulse frequency-division or pulse frequency-magnification set for this operation.

•When both interval mode and pulse proportional control operation are simultaneously set, the pump will operate in accordance with pulse frequency-division or pulse frequency-magnification set for this operation.\*1

\*1 The number of strokes will be the value set in each program.

The following combination of functions can also be used besides the abovementioned combination.



Model code \*Not all model combinations are possible. When selecting the pump model, first check "Specification" and "Liguid-end material".

PW -		<b>)E</b> – 4	×9PV			- JPL
1 Series name	2 Model(discharge volume standard)	3 Liquid-end material	4 Hose standard (size/material)	5 Joint specification	6 Applicable standard	7 Power plug
PW: Standard (pulse input) type PWM: Analog input type PWT: Timer control type	[General chemical liquid injection model w/relief valve] 30R : 30mL/min 60R : 60mL/min 100R : 100mL/min [General chemical liquid injection model] 30 : 30mL/min 60 : 60mL/min 100 : 100mL/min 200 : 220mL/min*1	VTCE VTCF FTCE FTCF FTCT 6TCT	4x9 PVC 6x11 PVC 6x8 PE/FEP/PTFE 1/4"x3/8" PE/FEP	W : Standard	S : Standard CE : CE marking -compatible	EUP : Euro plug ULP : UL plug AUP : Australia plug UKP : UK plug JPL : Japan lead wire
	[Boiler chemical liquid injection model w/relief valve*2] 30R : 28mL/min [Boiler chemical liquid injection model*2] 30 : 28mL/min [High-pressure chemical liquid injection model *2]	VTCET	4×6 PA	BW : Boiler		
	30 : 25mL/min	VTCET	4×6 PA RC 1/4 FNPT 1/4	PW : High-pressure		
	[High-viscosity chemical liquid injection model] 60 : 60mL/min 100 : 100mL/min	VTCF	12x18 PVC	V : High-viscosity		

\*1 SAFE mode and ECO mode cannot be used. The information pertaining to liquid-end parts only applies to the VTCE/VTCF type. \*2 SAFE mode cannot be used.

#### Performance specifications

	_	Model					P	W/PWM/PW	Т				
		_		30R/30		30	30R/30	30		60R/60		60	60
Specification	on		VTCE/VTCF	FTCE/FTCF	FTCT	6TCT	VTCET(boiler)	VTCET(high-pressure)	VTCE/VTCF	FTCE/FTCF	FTCT	6TCT	VTCF(high-viscosity)
		mL/min		30		27	28	25		60		55	60
Max.discha	arge volume*1	L/H		1.8		1.62	1.68	1.5	3.6			3.3	3.6
		US G/h		0.47		0.42	0.44	0.39	0.95		0.87	0.95	
	MPa			0.7/1.0 *2		0.5	1.5	2		0.7/1.0 *2		0.5	1.0
Max.discha	arge pressure*1	bar	7/10 *2		5	15	20	7/10 *2			5	7	
	psi			101.5/145		72.5	217.5	290		101.5/145		72.5	145
Stroke spe	ed	·				1~300	strokes/min	(Enables set	ting in 1-strok	e units)			
Stroke leng	gth					0.5 ^	~ 1 mm (Ena		ent using the	dial)			
Connection	2	Discharge side	4 x 9(PVC braidedhose) 6 x 8(PE)	6 x 8(PE)	6 x 8(FEP)	6 x 8(PTFE)	4 x 6(PA)	4 x 6(PA) Rc 1/4 FNPT 1/4	6 x 11(PVC braided hose) 6 x 8(PE)	6 x 8(PE)	6 x 8(FEP)	6 x 8(PTFE)	12 x 18
	e:I.D x O.D)	Suction side	1/4"x3/8"(PE)	1/4"x3/8"(PE)	1/4"x3/8"(FEP)	0 X 8(PIFE)	4 x 9(PVC braided hose)		1/4" x 3/8"(PE)	1/4"x3/8"(PE)	1/4"x3/8"(FEP)	0 X 8(PIFE)	(PVC braided hose)
(nose/tube	9.1.D X O.D)	Air-release	4 x 6	(soft PVC h	ose)	-		4 x 6	(soft PVC ho	se)			_
Viscosity o	of transfer liquid						50mPa •	s or less					3,000mPa • s or less*3
Temperatu	ure of transfer liqui	d		0 ~ 40°C(no freezing allowed)									
Ambient te	emperature			0 ~ 40℃									
Environme	ental resistance			IEC standard:IP65 or equivalent (dust-&water-resistance)									
Insulation	class		В										
	Rated voltage		AC 100 to 240 V (±10%)										
	No. of phases/F	requency					1-pł	nase/50 or 60	) Hz				
Power	Max. current			2	A					2.5 A			
supply	Max. power con	sumption		200	VA					250 VA			
	Avg. power con:	sumption		15	W					18 W			
	Cable						Cabty	re cable (φ5	i~10)				
Weight		kg	1.8	1.8	1.8	3.2	1.9	1.9	1.9	1.9	1.9	3.3	1.9

	Model			PW/PW	M/PWT			
	_		100R/100		100	100	200	
Specification		VTCE/VTCF	FTCE/FTCF	FTCT	6TCT	VTCF(high-viscosity)	VTCE/VTCF	
	mL/min		100		95	100	220	
Max.discharge volume*1	L/H		6		5.7	6	13.2	
	US G/h	1.58			1.5	1.58	3.48	
	MPa		0.7		0.5	0.7	0.2	
Max.discharge pressure*1	bar		7		5	7	2	
	psi		101.5		72.5	101.5	29	
Stroke speed			$1\sim$ 300 stro	kes/min (Ena	ables setting	in 1-stroke u	nits)	
Stroke length			$0.5 \sim 1 ~ n$	nm (Enables	adjustment (	using the dial	)	
Connection	Discharge side Suction side	6 x 11(PVC braided hose) 6 x 8(PE) 1/4" x 3/8"(PE)	6 x 8(PE) 1/4"x3/8"(PE)	6 x 8(FEP) 1/4"x3/8"(FEP)	6 x 8(PTFE)	12 x 18 (PVC braided hose)	6 x 11(PVC braided hose) 6 x 8(PE) 1/4" x 3/8"(PE)	
(hose/tube:I.D x O.D)	Air-release	4 x 6	(soft PVC h	ose)	-	-	-	
Viscosity of transfer liquid			50mPa •	s or less		3,000mPa • s or less*3	50mPa • s or less	
Temperature of transfer liquid	ł	$0 \sim 40^{\circ}$ C(no freezing allowed)						
Ambient temperature		$0 \sim 40^{\circ}$ C						
Environmental resistance		IEC standard:IP65 or equivalent (dust-&water-resistance)						
Insulation class		В						
Rated voltage				AC 100 to 2	240 V (±10%	»)		
No. of phases/F	requency			1-phase/	50 or 60 Hz			
Power Max. current		2.5 A						
supply Max. power con	250 VA							
Avg. power cons	Avg. power consumption			1	8 W			
Cable	Cabtyre cable ( $\phi$ 5~10)							
Weight	kg	1.9	1.9	1.9	3.3	1.9	4	

\*1 Conditions:Clean water, room temperature. \*2 0.7MPa (7bar) for models w/relief valve(R type) whereas 1.0MPa (10bar) for models w/o relief valve. 3 When transferring high-viscosity liquids, the maximum discharge volume may be lower than the specified volume depending on the characteristics of the liquid and operating conditions. Consult TACMINA separately when transferring high-viscosity liquids.

#### Control function specifications

			•			
	Item		PW	PWT	PWM	
	Ana	log input	_	_	One port: analog signal (DC 4 to 20 mA, input resistance: approximately 110 Ω)	
Signal	Digital	Input	(no-voltage contact maximum no. of pulses minimum pulse width One port: pun (no-voltage contact maximum no. of pulses minimum pulse width	s: 1200 pulses/minute, n: 25 ms [ON period]) np stop signal t or open collector, s: 1200 pulses/minute, n: 25 ms [ON period])	One port: pump stop signal (no-voltage contact or open collector, maximum no. of pulses: 1200 pulses/minute, minimum pulse width: 25 ms [ON period])	
		Output	. (D	e signal s) ignal s)		
		Number of strokes	1 to 300 (E	nables setting in 1-st	roke units)	
	Manual operation	Discharge volume control	0.1 to maximum discharge volume (Setting in 0.1mL/min. units enabled)			
	Pulse proportional	Division	1/999~1/1			
	control	Magnification	1~999			
	Analog pro	portional control			Proportional band/set point method	
		Interval		1 pattern (1~9999min.)		
Onintral		DAY		9pattern		
Control	Timer	WEEK		7pattern	_	
		DAY + Interval		0		
		WEEK + Interval		0	_	
	Timer + Pulse proportional	Division		1/999~1/1		
	control	Magnification		1~999	0	
	External o	peration signal	0	0	0	
	Externa	al stop signal	0	0	0	
	Operatio	on sync pulse	0	0	0	
	Alar	m output	0	0	0	

Accessories	* Power cable (2 m) is attached.
Accessores	


					P١	N/PWM/PV	VT		
Item		Ge	enera	l che	mical mod	lel	Boiler	High pressure	High viscosity
	VTCE VTCF FTCE FTCF		FTCT	6TCT	VTCET	VTCET	VTCF		
Hose / Tube	3m 3m		3m	3m	Discharge side: 2m <sup>*4</sup> Suction side: 1m		3m		
Relief / air-release hose*1	111	1m*2 1n			n			1m	
Anti siphonal check valve		1set(I	R1/2)	2) 1 set (R1/2 or R3/8)		1set <sup>*4</sup> (R1/2)			
Foot valve					1set				
Ceramic weight	-	_		1s	et		_	_	
Hose pump			_	_		1set	_	_	1set
Cable ties (INSULOK®) for relief hose (spare)*3		1				— 1 —			_
Pump mounting nuts / bolts	2				2 s	2 sets (M5x30)			
Instruction manual		10				1copy			

\*1 This hose is already attached to models with the simple relief valve.
\*2 This hose is not supplied with 200-type models.
\*3 This accessory is supplied with models with the simple relief valve.
\*4 These items are supplied only when 4x6 PA is selected for the discharge-side connection.
\* The signal cable is sold separately. The signal cable is included when the PWM and the chemical injection PTS series are purchased as a set.

#### External dimensions


•PW/PWM/PWT/-30\_/60\_/100\_


	A	В	С	D
VTCE/VTCF	216	152	76	76
FTCE/FTCF/FTCT	237	195	97.5	97.5
VTCF (High viscosity)	233	167.5	92.5	75
VTCET(BWJ)	230	166	90	76
VTCET(PWJ)	233	169	93	76



●PW/PWM/PWT-200

•PW/PWM/PWT/-30\_/60\_/100\_ (6TCT)





\* The shape and dimensions differ slightly depending on the liguid-end material and connection type

#### Liquid-end Material

Liquid-e	nd Mater	ial			* Also refer to the "Corrosion-resistance Table" on page 26.				
Model Part	VTCE	VTCF	FTCE	FTCF	FTCT	6TCT	VTCF (High-viscosity)	VTCET (Boiler/High-pressure)	
Pump head	PVC	PVC	PVDF	PVDF	PVDF	SUS316	PVC	PVC	
Diaphragm	PTFE	PTFE	PTFE	PTFE	PTFE	PTFE	PTFE	PTFE	
Check ball	Ceramic	Ceramic	Ceramic	Ceramic	Ceramic	Ceramic	Ceramic	Ceramic	
O-ring	EPDM	Fluoro rubber	EPDM	Fluoro rubber	Special fluoro rubber	PTFE	Fluoro rubber	EPDM	
Valve seat	EPDM	Special fluoro rubber	EPDM	Special fluoro rubber	PTFE			PTFE	
Joint	PVC	PVC	PVDF, PP	PVDF, PP	PVDF	SUS316	PVC	PVC, SUS304 <sup>*1</sup>	
Ball stopper	PVC	PVC	PVDF	PVDF	PVDF			PVC	
Valve stopper						PTFE	PE		
Compression coil spring							SUS304		

\*1 Only when 4x6 PA is selected for the discharge-side connection.







#### **Common Functions**

#### **Direct Entry of Injection Amount**

The injection amount can be set according to three patterns: [By stroke speed]

Setting range: 1 to 300 strokes/min

PZD

(minimum setting increment: 1 stroke/min)

#### [By discharge volume]

Setting range: 0.1 to (maximum discharge volume of selected model) mL/min (minimum setting increment: 0.1 mL/min)

#### [By percentage]

Setting range: 1 to 100% (minimum setting increment: 1% (3 strokes/min))

#### **Extensive Range of Liquid-end Materials**

#### VTCE/VTCF

6TCT

Material: PVC Application example: Transfer/injection of general chemicals

Material: Stainless steel

Application example:


Transfer/injection of

solutions/special chemicals


(SUS316·304)

#### Wide Voltage **Range Power Supply**

There is no need to worry about site power supply voltage or voltage fluctuations since it can be used with AC100 to 240 V  $(\pm 10\%)$  power supplies. You can also keep it in



stock safely since it can be used for a variety of sites and applications.



#### **3-directional Pump Head**







\* This feature is limited depending on the operating conditions. Consult us for details.



FTCT Material: PVDF Application example: Transfer/injection of special chemicals (e.g. strong and mixed acids)

#### PZD

#### Quick & Easy Calibration


The PZD Series is provided with easy calibration function for accurate pump calibration. Just push the button to automatically discharge 300 strokes' worth of chemical and enter the actual discharge volume that you will be measuring. This is all you need to do for accurate calibration.



PZi4 PZi8

#### Analog-Input Proportional Control


The injection amount (stroke frequency: 0 to 300 strokes/min) can be set according to the analog input signal (PZi4: 4 to 20 mA, PZi8: 0 to 20 mA or 4 to 20 mA) from an external device.



#### PZi4 PZi8

#### External operation & stop control


The pump can be turned on and off using a input signal from an external device.



#### PZi4 PZi8

#### Pulse-Input Proportional Control & External Stop Input Control


Pump ON/OFF can be controlled by an external stop input signal. Also, the injection amount (1/9999 to 9999 strokes/pulse) can be set according to the pulse input signal from an external device.



#### PZi8

#### 2-point Level Switch Control

Control such as alarm display and output, and pump stop is performed in accordance with the remaining amount of chemicals.




#### Count (batch) & Interval (timer) Operation

#### Count setting

1 to 9999 strokes (x1, x10, x100, x1000)

#### Interval setting

ON time : 1 to 9999 min OFF time : 1 to 9999 min




#### Specification: PZD

	M	lodel		30	00		500				
Specif	ication		VTCE	VTCF	FTCT	STCT	VTCE	VTCF	FTCT	STCT	
		mL/min	3	60	33	30	54	40	5.	0	
Max.disc	harge volume*	L/h	2	1.6	19	9.8	32	2.4	30.6		
	•	US G/h	5	.7	5.	22	8.	55	8.	07	
		MPa		0	.3			0.	2		
Max.disch	narge pressure*	bar		3	.0			2	.0		
	•	psi		4;	3.5			2	9		
Stroke s	peed						min (digital setting	1)			
Stroke le	ength		0.2 to 1.5 mm (manual dial)								
Connection	Discharge side 12 x 18 (PVC braided hose) 9 x 12 (PE) (PTEE)						12 x 18 (PVC braided hose) 9 x 12 12 x 15 (PE) (PTFE)				
(hose/tube: I.D x O.D)	Suction side	е	3/8"	PE) x 1/2" PE)	(P1	FE)	3/8":	?E) x 1/2" ?E)	(PT	FE)	
	Air-release						_				
	wable viscos					50 m					
	e temperatur	e		Am	bient temperature:	0 to 40°C/Transfer	• •	C (no freezing allow	ved)		
	humidity				150	35 to 8		· · · · ·			
	mental protection l				IEC standa	ard: IP65 or equiva	1.1.000 m	-resistance)			
Noise le		ocation									
Operation mode	Manual		Digital settings: 3 patt	Less than 85 dB gital settings: 3 patterns [stroke speed (1 to 300 strokes/min, in 1 stroke/min increments), discharge volume (in 0.1 mL/min increments), percentage (1 to 100%, in 1% increment							
	Rated vo	Itage		AC 100 to 240 V (±10%)							
Power	No. of phases/F	requency		1-phase/50 or 60 Hz							
supply	Maximum o	urrent				3.0	A				
	Power consu	mption				Max.: 500 VA	A/Ave.: 30 W				
Weigh			4.0	4.0 kg 4.2kg 6.0kg 4.0 kg 4.2kg 6.0kg							

#### Specification: PZi4/PZi8

		Ν	lodel		30	00		500					
Specif	icati	on		VTCE	VTCF	FTCT	STCT	VTCE	VTCF	FTCT	STCT		
			mL/min	30	60	33	30	5	40	5.	10		
Max. disc	harge	volume*1	L/h	21	.6	19	).8	3	2.4	30	).6		
	Ũ		US G/h	5	.7	5.	22	8	.55	8.	07		
			MPa			.3				).2			
Max.disch	arge p	ressure*1	bar		3	.0			2	2.0			
	J- P		psi		43	3.5				29			
Stroke s	peed					 ·	1 to 300 strokes/m	in (digital setting)		-			
Stroke I	ength	I				(	0.2 to 1.5 mm (adjust	table by manual dial	)				
Connection (hose/tube: I,D x O,D)		tion side		(PVC brai 9 x	x 18 ided hose) : 12 :E) x 1/2"	x 18 ided hose) x 12 PE) x 1/2"	12 x 15 (PTFE)						
1.D X Q.D/	ouc	1011 310	0	(P	E)			(F	PE)				
		release					4 x 6 (soft I	,					
Max. allo							50 mF						
Allowabl			e		Ambient temperature: 0 to 40°C/Transferring liquid: 0 to 40°C (no freezing allowed) 35 to 85% RH								
Ambient Environ			otion	IEC standard: IP65 or equivalent (dust-&water-resistance)									
Altitude d		<u> </u>				ILO Stallua	uvalent (dust-&water-resistance) than 1.000 m						
Noise le		anation	location					than 85 dB					
	Ana	log-Inpu	ut PZI4 :1 port : Analog signal (4 to 20 mA DC, input resistance: approx.110Ω)*2 PZI8 :1 port : Analog signal (4 to 20 mA DC, 0 to 20 mA, input resistance: approx. 110Ω)*2										
Signal	Digit		Input	1 port : Pu PZi8 : 2 ports: Hig 2 ports: Lor Sig	mp stop signal (no-volta h-speed pulse signal (no w-speed pulse signal (no gnal assignments : Una (4 selectable) Lev	-voltage contact or open of age contact or open colle -voltage contact or open o-voltage contact or open assigned, Pulse signal, S el Switch signal (only wh	ector, min. pulse width: collector, max. number of en collector, min. pulse v otop signal, Reset/Resta	50 msec (ON time)) f pulses: 7500 pulse/min, width: 50 msec (ON time rt signal, Alarm reset sig	min. pulse width: 4 msec	: (ON time))*2	cker is used),		
		0	Dutput		ulse signal (3 mA DC, nal assignments : Unassigne	25 V or less) ed, Solenoid-operation sync pu	lse signal, In-operation signal,	, Operation end signal, Lamp	alarm signal, Low tank-level a	larm signal (only when 2-point	Level Switch is used),		
				(	2 selectable) Pulse-In	put error signal, Analog-		-	rm signal (only when Flo	ow Cheker is used)			
Power su			necker*4	Disital actions: 2 ac	therme fetrelice encod (1	to 200 otrolico (min in 1	PZi8	,	1 ml (min in exempente)	noreceptone (1 to 1000/	in 10/ incremente		
	Man	Analog-	Input al control*5			to 300 strokes/min, in 1 portional Band (PB/v	,.		,.		,		
			iput al control*5		Control	possible by Frequen	cy-division (1/1 to 1	/9999) setting/Multi	plication (1 to 9999)	setting			
Operation mode	Auto	Count o (batch co	peration ontrol)			PZi8 o	nly : 1 to 9999 strok	es (x1, x10, x100, x	1000)				
mode	Auto	Interval of (timer co	operation ontrol)			PZi8 only	: ON time: 1 to 9999	min/OFF time: 1 to	9999 min				
		Externa input co	ontrol	"STP" flashing display, pump stopped									
			control*6	PZi8 only	: [Low tank-level a	larm] "E-02" display			alarm] "STP" flashin	g display and pump	stopped		
D	<u> </u>	ted vo	-				AC 100 to 24	. ,					
Power		phases/F					1-phase/50						
supply		imum c					3.0						
		er consu	Imption		-		Max.: 500 VA		-				
Weigh	t			4.0	kg	4.2 kg	6.0 kg	4.0	) kg	4.2 kg	6.0 kg		



Accessory

\* When "NON" is selected for power plug, the power cable(2m) is not provided.

Model		PZ	ZD		PZi4/PZi8				
Item	VTCE	VTCF	FTCT	STCT	VTCE	VTCF	FTCT	STCT	
Hose/Tube*1		3	m		3 m				
Anti-siphon check valve	1 s (R1/2 o	et r R3/8)	*2	1 set (R1/2)	1 : (R1/2 c	set or R3/8)	*2	1 set (R1/2)	
Foot valve	1 :	et	*2	1 set	1 set		*2	1 set	
Ceramic weight	1 :	et*3	-		1 set*3				
Pump mounting nuts/bolts				2 sets (1	2 sets (M5 x 30)				
Operation manual			1 set						

\*1 For details on the hose/tube aperture, see "Connection" for the respective model in "Specification" table on page 15. \*2 For the FTCT type, please purchase the valves separately. \*3 Only when PE tube is selected

**Liquid-end Material** 

\* Also refer to the "Corrosion-resistance Table" on page 26.


Model Part	VTCE	VTCF	FTCT	STCT						
Pump head	P۱	/C	PVDF	SUS304						
Diaphragm		PTFE								
Check ball		Ceramic								
O-ring	EPDM	Fluoro-rubber	PT	FE						
Valve seat	EPDM	Special fluoro-rubber	_	_						
Joint	P۱	/C	PVDF SUS304							
Ball stopper	P١	/C	PTFE (val	ve stopper)						

(F) G


174.5 83

181 85.5

#### External Dimension (mm)



\* The shape and dimensions differ slightly depending on the liquid-end material and connection type. \* The mounting pitch allows mounting from 87 to 110 mm.



+		φ118 (F)						
	Model	(A)	В	С	D	Е	(F)	G
	VTCE/VTCF	243	176	88	88	24.5	180	85.5
	FTCT/STCT	255.5	183	82.5	100.5	22	174.5	83





#### Large-capacity

Lineup of four models supporting large-capacity injection up to 1000 mL/min



#### High-viscosity

The PZiG series can also be used for the injection of polymer coagulant.



When transferring high-viscosity liquids, the maximum discharge volume may be lower than the specified volume depending on the characteristics of the liquid and operating conditions. Consult TACMINA separately when transferring high-viscosity liquids.

#### Direct Entry of Injection Amount

### The injection amount can be set according to three patterns: **[By stroke speed]**

Setting range: 1 to 300 strokes/min (minimum setting increment: 1 stroke/min)

#### [By discharge volume]

Setting range: 0.1 to (maximum discharge volume of selected model) mL/min (minimum setting increment: 0.1 mL/min)


#### [By percentage]

Setting range: 1 to 100% (minimum setting increment: 1% (3 strokes/min))



Wide Voltage

There is no need to worry about site power supply voltage or voltage fluctuations since it can be used with A C 100 to 240V ( $\pm$ 10%) p o w e r



supplies. You can also keep it in stock safely since it can be used for a variety of sites and applications.

#### Dust & Water resistance



IEC standard: IP65 or equivalent \* Avoid condensation and immersion in water.



Stroke-length

adjustment dial

Simple key Layout

CKELENGTH

1

Large 2-row LCD display w/ backlight

Function key SET/RESET key

#### Quick & Easy Calibration

The PZiG Series is provided with easy calibration function for accurate pump calibration. Just push the button to automatically discharge 300 strokes' worth of chemical and enter the actual discharge volume that you will be measuring. This is all you need to do for accurate calibration.



#### Extensive Range of Liquid-end Materials

\* For details, refer to the "Liquid-end Material" table on the following page.

VTCE/VTCF Material: PVC Application example: Transfer/injection of general chemicals




Transfer/injection of high-viscosity liquids

**sity type)** /C example:

FTCT Material: PVDF Application example: Transfer/injection of special chemicals (e.g. strong and mixed acids)


#### Analog-Input Proportional Control

The injection amount (stroke frequency: 0 to 300 strokes/min) can be set according to the analog input signal (4 to 20 mA DC) from an external device.



#### Pulse-Input Proportional Control & External Stop Input Control


Pump ON/OFF can be controlled by an external stop input signal. Also, the injection amount (1/9999 to 9999 strokes/pulse) can be set according to the pulse input signal from an external device.



\* For details on the Level Switch, see "Option" on the back cover.

#### 2-point Level Switch Control

Control such as alarm display and output, and pump stop is performed in accordance with the remaining amount of chemicals.




#### Count (batch) & Interval (timer) Operation

#### Count setting

1 to 9999 strokes (x1, x10, x100, x1000)


#### Interval setting

ON time : 1 to 9999 min OFF time : 1 to 9999 min



#### Example of Safe Hose Piping

for Fully Demonstrating the Performance of the PZiG




#### Specification

		N	lodel		3	300			500						
Specification				VTCE VTCF FTCT (high-viscosity) type			/high-viscosity	VTCE	VTCF FTCT		СТ	VTCF (high-viscosity type			
			mL/min			340				5	30				
Max. disc	harge	volume*1	L/h		2	20.4			31.8						
	Ŭ		US G/h		5	5.38			8.39						
			MPa	1	.0	0.5	1.0	1.0	0	.7	0.5	0.7	0.7		
Max. disch	narge p	pressure*1	bar	10	0.0	5.0	10.0	10.0	7	.0	5.0	7.0	7.0		
psi		psi	1	45	72.5 145		145	10	1.5	72.5	101.5	101.5			
Stroke s	peed	1					I	1 to 300 strokes/	min (digital setting)			1 1			
Stroke le	ength	ı					C	).3 to 1.5 mm (adju	stable by manual d	ial)					
Connection hose/tube:	Discharge side			(PVC bra	x 18 iided hose) PT 1/2	12 x 15 (PTFE)	FNPT 1/2	FNPT 3/4 MNPT 3/4 VP 20	(PVC brai	x 18 ded hose) T 1/2	12 x 15 (PTFE)	FNPT 1/2	FNPT 3/4 MNPT 3/4 VP 20		
I.D x O.D)		tion side			1 1/2			(Union Joint)				(Union Joint)			
May alla		ef /air-re			50 D				50mPa·s				3000mPa·s*2		
Max. allowable viscosity Allowable temperature					50 mPa·s	Ambiont to	mporature	3000 mPa·s*2	sferring liquid: 0 to 40°C (no freezing allowed)						
Ambient		<u> </u>	5			Ambient te	inperature		85% RH	o (no neezing anot	100/				
Environmental protection			ction				IEC stan	dard: IP65 or equiv		resistance)					
Altitude c	of insti	rallation I	ocation					Less tha	ın 1,000 m						
Noise level								Less th	an 85 dB						
	Ana	ιlog-Inpι	ut		gnal (4 to 20 mA DC,										
Signal	Digi	Input		2 ports: High-speed pulse signal (no-voltage contact or open collector, max. number of pulses: 7500 pulse/min, min. pulse width: 4 msec (ON time))*3 2 ports: Low-speed pulse signal (no-voltage contact or open collector, min. pulse width: 50 msec (ON time)) Signal assignments : Unassigned, Pulse signal, Stop signal, Start signal, ReseVRestart signal, Alarm reset signal, (4 selectable) Level Switch signal (only when Level Switch is used), Compulsive MAX operation signal											
			Dutput	2 ports: Pulse signal (10 mA DC, 25 V or less)     Signal assignments: Unassigned, Solenoid-operation sync pulse signal, In-operation signal, Running signal, Operation end signal, Lamp alarm signal,     (4 selectable) Low tank-level alarm signal (only when 2-point Level Switch is used), Pulse-Input error signal, Analog-Input error signal											
	Mar			Digital settings: 3 patterns [stroke speed (1 to 300 strokes/min, in 1 stroke/min increments), discharge volume (in 0.1 mL/min increments), percentage (1 to									%, in 1% increments		
		Analog- proportiona	al control*5			Cont	rol possib	le by Proportional Ba	and (PB) setting/Set Point (SP) setting						
		Pulse-In proportiona		Control possible by Frequency-division (1/1 to 1/9999) setting/Multiplication (1 to 9999) setting											
peration mode	Auto	Count o (batch co						1 to 9999 strokes (	x1, x10, x100, x1000	)					
		Interval o (timer co	operation ontrol)				10	N time: 1 to 9999 min	/OFF time: 1 to 9999	min					
		Externa input co 2-point	ontrol						play, pump stopped						
		Switch c	control*6		[Low tank-level ala	arm] "E-02" o	displayed	and alarm output/[Lo	wer tank-level alarm	] "STP" flashing dis	play and pu	imp stoppe	d		
Deurer		ted vo	-						240 V (±10%)						
Power		f phases/ Fr							50 or 60 Hz						
supply		cimum c							0 A						
		er consu	mption						A/Ave.: 100 W						
Weigh	1							11	kg						

\*1 Conditions: Clean water, room temperature \*2 When transferring high-viscosity liquids, the maximum discharge volume may be lower than the specified volume depending on the characteristics of the liquid and operating conditions. Consult TACMINA separately when transferring high-viscosity liquids. \*3 Combined use of Analog-Input signal and high-speed pulse signal not possible. \*4 For a detailed explanation on signals, see "Digital Signal" on page 26. \*5 For details, see "Analog-Input Proportional Control" and "Pulse-Input Proportional Control" on page 18. \*6 When 2-point Level Switch is used

Model Code \* Not all model combinations are possible. When selecting the pump model, first check "Specification" and "Liquid-end Material".



#### Accessory

\* The 4-pin/8-pin cable (2 m or 5 m selectable) is an option.

Model	VTCE	VTCF	FTCT	VTCF (High-viscosity type)				
Hose/Tube*1		3 m						
Anti-siphon check valve		1 set (R1/2 or R3/8)	*2	—				
Strainer		_						
Pump mounting nuts/bolts(M5 x 30)	4 sets							
Operation manual	1 set							

\*1 For details on the hose/tube aperture, see "Connection" for the respective model in "Specification" table above. \*2 For the FTCT type, please purchase the check valve and strainer separately.

#### Specification

$\overline{}$		Ν	lodel		7	00			10	000			
Specif	icat	ion		VTCE	VTCF	FTCT	VTCF (high-viscosity type	VTCE	VTCF	FTCT	VTCF (high-viscosity type		
			mL/min		7	60		1000					
Max. disc	harge	volume*1	L/h		4!	5.6		60.0					
			US G/h			.03		15.84					
			MPa		0	.4			0	).3			
Max disch	Max. discharge pressure*1 bar					.0		3.0					
psi						58		43.5					
Stroke s	2000	1	psi			00	1 to 300 strokes/n	in (digital patting)		3.5			
Stroke le						0	3 to 1.5 mm (adjus		al)				
STOKE							FNPT 3/4		ai)		FNPT 3/4		
Connection	Dise	charge s	side		x 18	12 x 15	MNPT 3/4		<18	12 x 15	MNPT 3/4		
(hose/tube:	Suc	tion side			ded hose) T 1/2	(PTFE) FNPT 1/2	VP 20		ded hose) T 1/2	(PTFE) FNPT 1/2	VP 20		
I.D x O.D)	Suc		8		1 1/2		(Union Joint)		1 1/2	110111/2	(Union Joint)		
		ef /air-re					-						
Max. allo			-		50mPa·s		3000mPa·s*2		50 mPa·s		3000 mPa·s*2		
Allowabl			e	Ambient temperature: 0 to 40°C/Transferring liquid: 0 to 40°C (no freezing allowed) 35 to 85% RH									
Ambient						150							
Environ						IEC standa	ard: IP65 or equiva		resistance)				
Altitude c		rallation I	ocation				Less that Less that	,					
Noise le		log-Inpi		1 port : Apolog cign	al (4 to 20 mA DC inc	out resistance: approx.							
Signal	Digi	ital*4	Input Dutput	2 ports: High-speed pulse signal (no-voltage contact or open collector, max. number of pulses: 7500 pulse/min, min. pulse width: 4 msec (ON time))*3     2 ports: Low-speed pulse signal (no-voltage contact or open collector, min. pulse width: 50 msec (ON time))     Signal assignments: Unassigned, Pulse signal, Stop signal, Start signal, Reset/Restart signal, Alarm reset signal,     (4 selectable) Level Switch signal (only when Level Switch is used), Compulsive MAX operation signal     2 ports: Pulse signal (10 mA DC, 25 V or less)     Signal assignments: Unassigned, Solenoid-operation sync pulse signal, In-operation signal, Running signal, Operation end signal, Lamp alarm signal,									
				(2 selectable) Low tank-level alarm signal (only when 2-point Level Switch is used), Pulse-Input error signal, Analog-Input error signal									
	Mar	nual		Digital settings: 3 patterns [stroke speed (1 to 300 strokes/min, in 1 stroke/min increments), discharge volume (in 0.1 mL/min increments), percentage (1 to 100%, in 1% increments)]									
		Analog- proportiona Pulse-In					by Proportional Bar						
Operation			peration		Contro		1 to 9999 strokes (x	1/9999) setting/Multiplication (1 to 9999) setting					
mode	Auto	(batch co Interval c (timer co	operation				time: 1 to 9999 min/						
		Externa input co	al stop				"STP" flashing disp	olay, pump stopped					
		2-point Switch o	Level control*6	[L	ow tank-level alarm	] "E-02" displayed ar	nd alarm output/[Lov	ver tank-level alarm	"STP" flashing dis	play and pump stop	ped		
	Ra	ted vo	Itage				AC 100 to 2						
Power	No.o	f phases/Fi	requency				1-phase/5	0 or 60 Hz					
supply	Max	cimum c	current				4.0	Α (					
	Pow	er consu	Imption				Max.: 750 VA	/Ave.: 100 W					
Weigh	t						11	kg					
								-					


\*1 Conditions: Clean water, room temperature \*2 When transferring high-viscosity liquids, the maximum discharge volume may be lower than the specified volume depending on the characteristics of the liquid and operating conditions. Consult TACMINA separately when transferring high-viscosity liquids, the maximum discharge volume may be lower than the specified volume depending on the characteristics of the liquid and operating conditions. Consult TACMINA separately when transferring high-viscosity liquids, the maximum discharge volume may be lower than the specified volume depending on the characteristics of the liquid and operating conditions. Consult TACMINA separately when transferring high-viscosity liquids, set "A a Combined use of Analog-Input signal and high-speed pulse signal not possible. \*4 For a detailed explanation on signals, see "Digital Signals" on page 26. \*5 For details, see "Analog-Input Proportional Control" and "Pulse-Input Proportional Control" on page 18. \*6 When 2-point Level Switch is used


#### Liquid-end Material

\* Also refer to the "Corrosion-resistance Table" on page 26.

Model	VTOE	VITOE	FT	ст	VTCF			
Part	VTCE	VTCF	300/500/700	1000	(high-viscosity type)			
Pump head	P	/C	PVI	)F	PVC			
Diaphragm		PTFE						
Check ball	Ceramic							
O-rings	EPDM	Fluoro-rubber	PTF	E	Fluoro-rubber			
Valve seat	EPDM	Special fluoro-rubber	-					
Joint	P	/C	PVI	)F	PVC			
Ball stopper	P	/C	PTFE(valve stopper)	—	-			
Ball guide	-	-	_	PVDF	PVC			
Compressed coil spring	-	_	-		SUS304			

#### External Dimension (mm)





VTCF (high-viscosity type)

Model	A	В	С	D	E	F
300/500/700	115	97	212	285	49.5	246
1000	128	128	256	298	53.5	253

PZiG







Digital-input/output

Analog-input

**Timer Control** 

Digital-input/output &

Digital-input/output &



CLPZ No-input

#### Two mechanisms for preventing gas lock

**CLPW** 

**CLPWM** 

**CLPWT** 

#### Easy-to-check trapped air



The transparent acrylic pump head, which has an innovative design to minimize dead space, enables the operator to check the trapped air at a glance.




#### Air block mechanism


DCL series pumps are equipped with a degassing joint as standard equipment. The degassing joint prevents intrusion of air that causes gas lock.

Prevents intrusion of maximum 15cc of air.



In-line type automatic air-release mechanism DCL and CL series are equipped with an air-release mechanism designed using a new concept. The in-line air-release mechanism of these models assures the elimination of air that is trapped in the pump head and automatically prevents the discharge trouble caused by gas lock.






#### Air-release performance


Comparison of the time required to purge air that is trapped in the pump head between CLPW and previous models (CLPZD, ARPZD).

Test conditions (Discharge pressure: 1.0MPa, air volume: 0.1mL) Test conditions (Discharge pressure: 1.0MPa, air volume: 0.5mL)



#### Prevention of trouble caused by crystallization

#### Anti siphonal check valve that prevents clogging at the injection point



#### Alarm function for notifying injection trouble



When injection trouble occurs, an alarm is emitted to warn this condition.

For details, see "Higher Safety" on page 7.

[Usage Precaution]

When diluting sodium hypochlorite, use pure water or water processed with a water softener. Otherwise the pump may malfunction or discharge trouble may result. Model code \*Not all model combinations are possible. When selecting the pump model, first check "Specification" and "Liguid-end material".

DCLPW	- <u>30</u> -	ATCF -	- <mark>4×9</mark>	_	- W -	- S -	JPL B
1 Series name	2 Control type	3 Model (discharge volume standard)	4 Liquid-end material	5 Hose standard (size/material)	6 Joint specification	Z Applicable standard	8 Power plug
DCLPW : Air block and in-line type automatic air- release functions CLPW : In-line type automatic air-release function	None : Standard (pulse input) type M : Analog input type T : Timer control type	[W/ relief valve] 30R: 30mL/min 60R: 60mL/min 100R: 90mL/min [W/O relief valve] 30 : 30mL/min 60 : 60mL/min 100 : 90mL/min	ATCF	4×9PVC 6×11PVC 6×8PE 1/4"×3/8"PE	W: Standard	S: Standard CE: CE marking -compatible	EUP:Euro plug ULP:UL plug AUP:Australia plug UKP:UK plug JPL:Japan lead wire
CLPZ	None : No-input	[W/ relief valve] 30R: 30mL/min [W/O relief valve] 30 : 50mL/min	ATCF	4×9PVC 6×11PVC 6×8PE 1/4"×3/8"PE	W: Standard	S: Standard CE: CE marking -compatible	EUP:Euro plug ULP:UL plug AUP:Australia plug UKP:UK plug JPL:Japan lead wire

#### Specifications

	Model			DCL	.PW			CLPW					CLPZ						
Specification		30R	60R	100R	30	60	100	30R	60R	100R	30	60	100	30R	60R	100R	30	60	100
Max.discharge	mL/min	30	60	90	30	60	90	30	60	90	30	60	90	30	60	100	30	60	100
volume	L/H	1.8	3.6	5.4	1.8	3.6	5.4	1.8	3.6	5.4	1.8	3.6	5.4	1.8	3.6	6	1.8	3.6	6
voluttie	US G/h	0.47	0.95	1.42	0.47	0.95	1.42	0.47	0.95	1.42	0.47	0.95	1.42	0.47	0.95	1.58	0.47	0.95	1.58
Max.discharge	MPa	0	0.7			1.0 0.7		0	.7		1.0		0.7	0.7 0		0.4	1.0	0.8	0.4
U U	bar	7	.0		10.0		7.0	7	.0		10.0		7.0	7.0		4.0	10.0	8.0	4.0
pressure	psi	10	1.5		145		101.5	10	1.5		145		101.5	101.5		58	145	116	58
Stroke sp	eed			11	to 300 stroke	s/min	(Enabl	es setting in	1-stro	ke unit	ts)			15 to	0 300 s	trokes	min (dial se	tting)	
Stroke ler	ngth				0.5~1 mm	(Enat	les ad	justment usi	ng the	dial)					Fi	ixed at	1.0 mm		
	Discharge side	$4 \times 9$ (PVC braided hose) $6 \times 8$	6 × (PVC brain 6 >	ded hose)	$4 \times 9$ (PVC braided hose) $6 \times 8$	6 × PVC brai(PVC brai)	ded hose)	$4 \times 9$ (PVC braided hose) $6 \times 8$	6 × (PVC brai	ded hose)	$4 \times 9$ (PVC braided hose) $6 \times 8$		: 11 ded hose) < 8	$4 \times 9$ (PVC braided hose) $6 \times 8$	6 × (PVC brai	ided hose)	$4 \times 9$ (PVC braided hose) $6 \times 8$	6 × (PVC braid 6 ×	ded hose)
Connection (hose/tube:I.D × O.D)	Suction side	(PE) 1/4" × 3/8" (PE)	(P 1/4" > (P	3/8"	(PE) 1/4" × 3/8" (PE)	(P 1/4" > (P	3/8"	(PE) 1/4" × 3/8" (PE)	(P 1/4" > (P	< 3/8"	(PE) 1/4" × 3/8" (PE)		E) < 3/8" E)	(PE) 1/4" × 3/8" (PE)		'E) × 3/8" 'E)	(PE) 1/4" × 3/8" (PE)	(P 1/4" > (P	3/8"
-	Air-release	4 × 6 (soft PVC hose)						4 × 6 (soft	4 × 6 (soft PVC hose) 4 × 6 (soft PVC hose)					-	_				
-	Degassing joint*3	1	/4" × 3	/8" (so	oft PVC hose	)							-	_					
Viscosity of trar	nsfer liquid								50	)mPa•	s or less								
Temperature of tr	ansfer liquid							0	~40°C	(no fre	ezing allowe	d)							
Ambient temp	perature									0~4	40°C								
Environmental	resistance						IEC	standard:IP	65 or e	equival	lent (dust-&w	ater-re	esistar	ice)					
Weight	kg	2	2	.1	2	2	.1	1.8	1.	9	1.8	1.	9	1.7	1.	.8	1.7	1.8	8
Conditions: Clean water, room temperature. 20 7 M De (10) and the control functions, refer to the specifications of PW series on pages 11 and 12.																			

<sup>12</sup> Conditions: Usan water, room temperature. <sup>12</sup> C.7MPa (2har) for models wirelief valve(R type) whereas 1.0MPa (10bar) for models w/o relief valve. <sup>13</sup> Provided for the DCLPW series only.

#### Liquid-end materials

Item	DCLPW	CLPW	CLPZ					
Pump head	Acrylic(PMMA)							
Diaphragm	PTFE							
Check ball								
O-ring	Fluoro rubber							
Valve seat		Special fluoro rubber						
Packing	PTFE							
Joint	PVC							
Degassing joint	PVC	/c —						
Ball stopper	PVC							

#### Accessories


\* Power cable(2m) is attached.

Item	DCLPW	CLPW	CLPZ				
Hose/tube	3m						
Relief / air-release hose*1	11	m					
Degassing joint	1 set (hose already attached)						
Anti siphonal check valve	1 set (R1/2)						
Foot valve			1 set				
Cable ties (INSULOK®) for relief hose (spare)*2	1pie	ece					
Pump attachment bolts and nuts	1 set						
Operating instructions	1 сору						
*1 The air purge hose with relief	valve is already attached to this pump.						


1 The air purge hose with relief valve is already attached to this pump. \*2 This accessory is supplied for models with the relief valve (R type). \* The signal cable is sold separately. The signal cable is included when the \_PWM and the chemical injection PTS series are purchased as a set.


#### External dimensions


OCLPW/DCLPWM/DCLPWT



#### ●CLPW/CLPWM/CLPWT










#### Automatic Relase of Air in Pump Head

Dead space inside the pump head has been limited to the bare minimum to prevent air entry and build up. Should air get into the pump, it is automatically released.



#### At-a-glance Inspection of Air Entry




The transparent acrylic pump head allows you to check at-a-glance if air has entered.

#### Prevention of Clogging at Injection Point

When injecting sodium hypochlorite, it reacts with calcium in the raw water that flows through the main piping and forms crystals at the injection point. The "Anti-siphon check valve with a duck-bill cap" was developed to solve this problem. This check valve solves all of your worries when injecting sodium hypochlorite, including overfeed and siphoning.





#### Specification

Model				ARPZ						
			31	61	12					
		mL/min	27	54	93					
Max.disc	harge volume*	L/h US G/h	1.62	3.24	5.58					
			0.42	0.85	1.47					
Max. discharge pressure*		MPa	1.0	0.8	0.4					
		bar	10.0	8.0	4.0					
		psi	145	116	58					
Stroke s				15 to 300 strokes/min (dial setting)						
Stroke I	ength			Fixed at 1.0 mm						
Connection	Discharge side		4 x 9 (PVC braided hose) 6 x 8	6 >	ded hose) < 8					
(hose/tube: I.D x O.D)	hose/tube: Suction side		(PE) 1/4" x 3/8" (PE)	(PE) 1/4" x 3/8" (PE)						
	Air-release			4 x 8 (soft PVC hose)						
Max. allo	owable viscos	ity	50 mPa·s							
	le temperatur	e	Ambient temper	Ambient temperature: 0 to 40°C/Transferring liquid: 0 to 40°C (no freezing allowed)						
	t humidity			35 to 85% RH						
	mental prote		IEC	IEC standard: IP65 or equivalent (dust-&water-resistance)						
	of instrallation I	ocation		Less than 1,000 m						
Noise le	-									
	Rated vo			AC 100 to 240 V (±10%)						
Power	No. of phases/F		2.0 A	1-phase/50 or 60 Hz	.5 A					
supply	Maximum o	Max.	2.0 A 200 VA		.5 A 50 VA					
	Power consumption				-					
Maint		Ave.	15 W		8 W					
Weight			1.7 kg	1.8 kg						

\* Conditions: Clean water, room temperature

+ Power apple (2m)is attached

#### Liquid End Material

Model Part	All Models
Pump head	Acrylic (PMMA)
Diaphragm	PTFE
Check ball	Ceramic
O-ring	Fluoro-rubber
Valve seat	Special fluoro-rubber
Joint	PVC
Ball stopper	PVC
Compressed coil spring	Hastelloy C


\* Also refer to the "Corrosion-resistance Table" on page 26.

Accessory


	* Power cable(2m)Is attached
Model Item	All Models
Hose/Tube*1	3 m
Air-release hose*1	1 m
Anti-siphon check valve	1 set (R1/2)
Foot valve	1 set
Ceramic weight	1 set*2
Pump mounting nuts/bolts	2 sets (M5 x 30)
Operation manual	1 set
+1 For details on the bose/tube apertur	

\*1 For details on the hose/tube aperture, see "Connection" for the respective model in "Specification" table above. \*2 Only when PE tube is selected

Model Code \* Not all model combinations are possible. When selecting the pump model, first check "Specification" and "Liquid-end Material".




#### External Dimension (mm)



 $\boldsymbol{*}$  The mounting pitch allows mounting from 87 to 110 mm.

#### **Application examples**



Neutralization tank Tank with pH recording instrument

#### Explanation

#### Digital Signal

#### \* Also refer to "Specification" for each model.

Input	Unassigned	Selected ports not to be unassigned						
	Pulse signal	Input signal required for Pulse-Input proportional control						
	Stop signal	Signal from an external device to stop the pump						
	Start signal	Signal from an external device to start the pump						
	Reset/Restart signal	Signal from an external device to reset the current value (count, time) during count operation (batch control) or interval operation (timer control) and to restart operation						
	Alarm reset signal	Signal from an external device to reset display/output of errors and alarms						
	Level Switch signal*1	Signal from the Level Switch installed in the tank to stop the pump operation * When 2-point Level Switch is used [Low tank-level alarm] "E-02" displayed and alarm output/ [Lower tank-level alarm] "STP" flashing display and pump stop						
	Compulsive MAX operation signal	Signal that forces the pump to run at MAX speed (300 strokes/min) regardless of operation mode						
Output	Unassigned	Selected ports not to be unassigned						
	Solenoid-operation sync pulse signal	One pulse signal to be output per stroke						
	In-operation signal	Signal to be output during the operation (including "in standby")						
	Running signal	Signal to be output during the pump is running (not including "in standby")						
	Operation end signal	Signal to be output when the preset number of strokes is reached during count operation (batch control)						
	Lamp a Alarm signal	Signal to be output when one of the following errors and alarms is detected						
	Tank-level alarm signal*1	Signal to be output when 2-point Level Switch is used and the volume of the chemical has fallen to the preset (low) level (Low tank-level alarm) * For Lower tank-level alarm, "STP" flashing display and pump stopped. However, no signal is output						
	Pulse-Input error signal	Signal to be output when the number of Pulse-Input signals momentarily exceeds the buffer size during Pulse-Input proportional control						
	Analog-Input error signal	Signal to be output when the Analog-Input signal goes outside of the specified range during Analog -Input proportional control (In the case of the 4 to 20 mA range, 3 mA or less or 22 mA or more. In the case of the 0 to 20 mA range, 0 mA or less or 22 mA or more)						

\*1 When Level Switch is used

#### Error & Alarm

#### \* Also refer to "By Function" on page 4.

Error/ Alarm	Memory-read error	Pump circuit- or program-related error					
	Tank-level alarm*1	Alarm when the chemical volume has fallen to the preset (low) level					
	Pulse-Input error	Error when the number of Pulse-Input signals momentarily exceeds the buffer size during Pulse-Input proportional co					
	Analog-Input error	Error when the Analog-Input signal goes outside of the specified range during Analog -Input proportional control (In the case of the 4 to 20 mA range, 3 mA or less or 22 mA or more. In the case of the 0 to 20 mA range, 0 mA or less or 22 mA or more)					

\*1 When Flow Checker is used

#### Corrosion-resistance Table

#### \* Also refer to "Liquid-end Material" for each model.

Liquid-end material Chemical (0 to 40°C)		VTCE	VTCF	FTCE	FTCF	FTCT	VTCET (for injection of boiler chemicals) *PZ/PW only		6TCT	STCT	ATCF	
Hydrochloric acid	HCℓ	—	to 20%	—	to 20%	to 38%	—					
Sulfuric acid	H2SO4	to 60%	to 80%	to 60%	to 80%	to 98%	_		98%		—	
Sodium hydroxide	NaOH	0	_	—	_		0	-	0		_	
Aqueous ammonia	NH4OH	0	_	—	_		0	-	0		_	
Sodium hypochlorite	NaCℓO	—	to 12%	_	to 12%		_		_		to 12%	
Hydrogen peroxide H2O2		—	to 30%	—	to 30%		-		to 90%		_	
Poly-aluminum chl	0						—					
Aluminum sulfate Al2 (SO4)3		0							0 -		_	
Polymer coagulan	_						to3000mPa·s*	_				

\* When transferring high-viscosity liquids, the maximum discharge volume may be lower than the specified volume depending on the characteristics of the liquid and operating conditions. Consult TACMINA separately when transferring high-viscosity liquids. \* The corrosion resistance of materials is greatly affected by temperature, concentration, UV rays, and other environmental conditions. For this reason, this selection table does not completely guarantee safety. \* The above figures are the corrosion resistance for pump liquid-end materials. Consult TACMINA separately regarding the corrosion resistance of hoses and tubes.

#### Degassing joint



#### Degassing joint is installed at the suction side of a pump. It separates absorbed air bubbles from the liquid to prevent air bubbles fi entering the pump head. from \*This joint is supplied with DCLPW series the as standard equipment.

#### Residual pressure exhaustion valve



Residual pressure exhaustion valve is directly connected to the discharge side of the pump so that the pipes can be safely purged of abnormal pressure that builds up. It also enables residual pressure and residual liquid to be safely discharged when maintenance services are performed.

#### Pulse generator type flowmeter



When using this flowmeter in combination with a Tacmina pulse signal input type metering pump, you can construct a simple and low-cost injection system proportional to the required flow rate.

#### Related equipments

Chemical injection system

Tank capacity

 Compact design and easy to assemble in equipment and assemble in equipment and install.
 You can start operation by simply connecting the power supply and piping.

30/50/120 L

Pump and tank combination





## **TACMINA CORPORATION**

Head Office:

Z-2-14 Awajimachi, Chuo-ku, Osaka 541-0047 Japan Tel.+81(0)6-6208-3974 Fax.+81(0)6-6208-3978 www.tacmina.com URL E-mail trade@tacmina.com

#### Flow checker



#### Flow checker is highly resistant to acid and alkalis and allows the injection operation of the pump to be checked at low cost. The pump-direct connection type and hose connection type are the two types of volume checkers available.

#### Relief valve (safety valve)

Relief valve automatically releases excessive pressure that builds up inside the discharge side pipes due to clogging of the pipes or while the discharge valve is closed. It can prevent accidents such as damage to the pump or piping.

#### Flow indicator and photoelectric sensor

These optional products enable you to check the injection operation visually as well as by means of a sensor.

#### Parts kit



Parts kit includes all required consumables in a set and is more economical than purchasing the parts separately. Since all consumables are packaged in one box, it also makes inventory management easier.

#### Back pressure valve



Back pressure valve prevents excessive liquid flow and siphon effect by sealing the outlet port of the liquid with a diaphragm, and by applying just enough force (back pressure) to overcome the fluid inertia force.

#### Float switch

Product designs and specifications are subject to change without notice for product improvement.

Float switch will stop the pump when the remaining volume of chemical liquid in the tank becomes low. They also cause an alarm to be emitted to notify you that it is time to refill the liquid. Two types of float switches are available, namely the float type with choices of one-point and two-point type sensors, and the electrode type, which is highly resistant to chemicals.





EC-054(14)-

2020/9/S-